



Engineering Technical Bulletin

No. 003-11-02

Revised – May 1, 2014

Curved BattenLok[®] Air Leakage and Water Penetration Test Data

PRODUCT

MBCI Curved BattenLok[®] profiles with mastic in battens.

TEST PROCEDURES

ASTM E 1680-95: Standard Test Method for Rate of Air Leakage Through Exterior Metal Roof Panel Systems.

ASTM E 1646-95: Standard Test Method Water Penetration of Exterior Metal Roof Panel Systems by Uniform Static Air Pressure Difference.

TEST RESULTS

Air Leakage was conducted with a uniform static air pressure differential of ± 1.57 psf & ± 6.24 psf. Water Penetration was conducted with a uniform static air pressure differential of 25.00 psf.

Water Penetration Test Results: No uncontrollable water leakage at 25 psf when five gallons per hour of water were sprayed per square foot of roof area.

The following are the test results extrapolated to the different widths to which they apply.

SUMMARY

Profile	ASTM E 1680-95 Air Leakage		ASTM E 1646-95 Water Penetration	
	Pressure Differential	Leakage Rate	Pressure Differential	Infiltration Rate
16" Curved BattenLok	± 1.57 psf	0.003 cfm / sq. ft.	25 psf	None
16" Curved BattenLok	± 6.24 psf	0.004 cfm / sq. ft.	25 psf	None

Copies of the independent test laboratory reports are available upon request.

Test Report No. T249-02 Dated: 9/16/2002